

NWO- CFA Cell, 8th Floor, Corporate Office,
Bharat Sanchar Bhawan, H.C. Mathur Lane
Janpath, New Delhi-110001
Tel No 011-23716688, Fax No 23766033
Email: nwocfa@bsnl.co.in



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

No. 7-1 /2018/NWO-CFA/MSE/Fire

Dated: ~~12.01.2018~~

To

23

The CGMs
Telecom Circle/Telecom Districts/Mtce Regions.

Sub: Regarding safety from Fire incidents.

Recently, a fire incident had occurred in Telephone Exchange Gogunta West Godavari, Eluru SSA, Andhra Pradesh Telecom Circle. Investigation committee has suggested the following measures to be taken to avoid such fire incident in future.

1. The Fire Detection System should be provided.
2. Window type AC should be replaced with split type AC unit.
3. 24 hrs manning is required to prevent such type of fire accidents.
4. Fire extinguisher should be kept outside the container which was kept inside at the time of the fire accident.

Apart from above, all existing guidelines & other instructions issued by this office time to time including engineering instructions on prevention of fire in telecommunication buildings & fire fighting should also be strictly followed.

This is issued with the approval of competent authority.

P.K.Sharma
23/01/18

(P.K.Sharma)
DGM (NWO-I-CFA)